



ISO 9001: 2000  
CERTIFIED

**MUNICIPAL SERVICE  
TUBING**

"CSA  CERTIFIED"

"WESTERN"

**POLYETHYLENE PIPE**

**SERIES 200**

**TYPE 111 PE-3408**

NOMINAL SIZE (in)	NOMINAL WALL (in)	NOMINAL O.D (in)	NOMINAL I.D (in)	WEIGHT C/FT (lbs)	LENGTHS (ft)	PRODUCT CODE
-------------------	-------------------	------------------	------------------	-------------------	--------------	--------------

**SERIES 200 - Working Pressure 200 PSI @ 23°C**

3/4"	0.097	0.875	0.681	10.2	100/150/200/300 400/500/1000*	MUNI-200-007
1"	0.125	1.125	0.875	17.0	100/150/200/300 400/500/1000*	MUNI-200-010
1-1/4"	0.153	1.375	1.069	25.0	100/150/200/300 500/1000*	MUNI-200-012
1-1/2"	0.181	1.625	1.263	36.0	100/200/250/500 1000*	MUNI-200-015
2"	0.236	2.125	1.653	58.0	100/200/500 1000*	MUNI-200-020

**\*NON-RETURNABLE REEL CHARGE: (EACH) \$11.00**

*PRICES SUBJECT TO CHANGE WITHOUT NOTICE*

"POLYTUBES<sup>®</sup>"  CERTIFIED "MUNICIPAL TUBING" IS MANUFACTURED TO CSA SPECIFICATION CAN/CSA B137.1/ AND IS FOR USE WITH CORPORATION FITTINGS.

**SERVICE FITTINGS WITH MUELLER 110<sup>®</sup> COMPRESSION CONNECTION SLP-11**



Straight three part union  
MUELLER 110<sup>®</sup> Conductive  
Compression Connection  
for CTS O.D.\* tubing - **both ends**

**H-15403**

1/2"	3/4"	5/8"	1"	1" x 3/4"	1-1/4"	1-1/2"	2"
50/ctn	25/ctn	50/ctn	20/ctn	25/ctn	15/ctn	10/ctn	7/ctn



Straight coupling  
MUELLER 110<sup>®</sup> Conductive  
Compression Connection  
for CTS O.D.\* tubing X  
M.I.P. thread


**H-15428**

1/2"	1/2" x 3/4"	3/4"	3/4" x 1/2"	3/4" x 1"	5/8" x 3/4"
50/ctn	50/ctn	25/ctn	50/ctn	25/ctn	50/ctn
1"	1" x 3/4"	1-1/4"	1-1/2"	2"	
25/ctn	25/ctn	5/ctn	10/ctn	10/ctn	

DRAWN BY	DM
DATE	YY/MM/DD
SCALE	1 :
LEGAL DESCRIPTION	
D.L.	
PLAN	
LOT	

DWG. TITLE	SPECIFICATIONS
------------	----------------

PROJECT	BUCKHORN COMMUNITY SEWER PROJECT
---------	--

 <b>REGIONAL DISTRICT</b> of Fraser-Fort George ENVIRONMENTAL SERVICES DEPT.	155 GEORGE STREET PRINCE GEORGE, BC V2L 1P8 PHONE: (250) 960-4400 FAX: (250) 562-8676 TOLL FREE: 1 800 667-1959
	DWG. NO. SP2