



ADDENDUM No. 2

**Invitation to Quote CS-16-05
Canoe Valley Recreation Centre Universal Access Doors Project**

The addendum is being issued prior to the closing of the Quote to provide further information, make changes to, or to clarify the Contract Documents and is to be read, interpreted and coordinated with all other parts of the Contract Documents. In the case of a conflict with the balance of the documents, this Addendum shall govern. **Bidders shall acknowledge receipt of this Addendum on the Quote Form and shall attach a signed copy of this addendum to their Quote.** This addendum shall form part of the Contract Documents.

1. Change to SCOPE OF WORK – Item 2.3 (page 14):

The following to be added:

- The Arena interior and exterior doors must be fire rated and integrate with the Fire Alarm system (to open in event of an incident). In order for a fire rated door to receive a low energy operator, the fire code requires that the power to the operator has to be disconnected during a fire alarm.



All inquiries related to this Invitation to Quote must be directed to:

Lyle Lewis, Facilities Manager
Phone: 250-569-3360
Fax: 250-569-3337
Email: llewis@rdffg.bc.ca