



## **Addendum No. 1**

### **Invitation to Tender – ES-16-08**

#### **Supply and Install of One Rooftop Chiller Unit 155 George Street**

The addendum is being issued prior to the closing of the tender to provide further information, make changes to, or to clarify the Contract Documents and is to be read, interpreted and coordinated with all other parts of the Contract Documents. In the case of a conflict with the balance of the documents, this Addendum shall govern. **Tenderers shall acknowledge receipt of this Addendum on the Tender Form and shall attach a signed copy of this addendum to their Tender.** This addendum shall form part of the Contract Documents.

#### **Change to Prices Tendered & Specifications, page 6:**

“According to the tender specifications, pricing is to be submitted for the supply, delivery, install and startup of one Rooftop Chiller Unit at 155 George Street pursuant to all terms and conditions outlined on the Specification Sheet herein, F.O.B. Prince George, BC and shall be good for the duration of ninety (90) days from the date of tender opening.”

#### **Shall be changed to read:**

“According to the tender specifications, pricing is to be submitted for the supply, delivery, install and startup of one Rooftop Chiller Unit, with power phase monitoring safety required, at 155 George Street pursuant to all terms and conditions outlined on the Specification Sheet herein, F.O.B. Prince George, BC and shall be good for the duration of ninety (90) days from the date of tender opening.”


#### **Addition to Prices Tendered & Specifications, page 6:**

“Add 3<sup>rd</sup> paragraph and Rooftop Floor Plan:

#### **Additions should read:**

“The Regional District is looking to replace its current Chiller unit which is a McQuay unit, model # AGZ045AS37-ER10 and serial # STNU990900133. Replacement unit will minimally meet the same specifications of current unit.”

Rooftop Floor Plan



Date: March 23, 2016

Signature \_\_\_\_\_

Name: \_\_\_\_\_

Inquiries relating to this ITT may be directed to:

Technical Inquiries:

Bryan Boyes  
 Utilities Leader  
 Regional District of Fraser-Fort George  
 155 George Street  
 Prince George, BC V2L 1P8  
 Phone: 250-960-4483 / Fax: 250-526-8676  
 Email: [bboyes@rdffg.bc.ca](mailto:bboyes@rdffg.bc.ca)

General Inquiries:

Petra Wildauer  
 General Manager of Environmental Services  
 Regional District of Fraser-Fort George  
 155 George Street  
 Prince George, BC V2L 1P8  
 Phone: 250-960-4483 / Fax: 250-526-8676  
 Email: [pwildauer@rdffg.bc.ca](mailto:pwildauer@rdffg.bc.ca)