



Addendum No. 1

Invitation to Tender ES-19-04

**Scale, Foundation and Accessory Installation at
Mackenzie Regional Transfer Station**

The addendum is being issued prior to the closing of the Invitation to Tender to provide further information, make changes to, or to clarify the Contract Documents and is to be read, interpreted and coordinated with all other parts of the Contract Documents. In case of a conflict with the balance of the documents, this Addendum shall govern. **Tenderers shall attach a signed copy of this addendum to their tender.** This addendum shall form part of the Contract Documents.

Question: Are the scale handrails, and the scale house platform and staircase to be painted or galvanized?

Answer: Handrails can be galvanized or steel sandblasted and painted. If the latter option is chosen, contractor must include rust proof coatings, including a high-quality primer and two coats of Rust Proof Epoxy Paint. Paint color to be 'Yellow'.

March 5, 2019

Addendum No. 1 Received.

Signature of Tenderer

Name of Tenderer

Inquiries relating to this ITT may be directed to:

Technical Inquiries:

Mircea Cvaci, P. Eng., MBA
Vice President & Civil Engineer
Sperling Hansen Associates
#8 - 1225 East Keith Road
North Vancouver, BC V7J 1J3
Phone: (604) 986-7723 Ext: 101
Email: mcvaci@sperlinghansen.com

General Inquiries:

Darwin Paton
Environmental Services Technician
Regional District of Fraser-Fort George
155 George Street
Prince George, BC V2L 1P8
Phone: 250 960-4482
Email: dpaton@rdffg.bc.ca