



August 26, 2020

## **SITE MEETING NOTES ADDENDUM No. 1**

### **Invitation to Tender CS-20-13 MCBRIDE FIRE HALL APRON**

*The addendum is being issued prior to the closing of the Invitation to Tender (ITT) to provide further information, make changes to, or to clarify the ITT Documents and is to be read, interpreted and coordinated with all other parts of the ITT Documents. In the case of a conflict with the balance of the documents, this Addendum shall govern. Proponents shall attach a signed copy of this addendum to their proposal submission, failure to do so may result in a non-compliant proposal. This addendum shall form part of the Contract Documents.*

This addendum is being provided in clarification to ITT CS-20-13 released August 12, 2020.

#### **Mandatory Site Meeting Notes:**

Staff: Bonnie Seitz, Community/Public Safety Assistant  
Korey Koretz, Fire Rescue Coordinator  
Dave Hruby, McBride Fire Chief

Representatives from the following firms attended the Mandatory Site Visit:  
Luxton Construction

#### Project Manager:

- Introduced staff in attendance and explained their roles;
- Brief overview of the project;
- Walked the site;
- Hosted proponent questions.

If any changes are needed during the construction phase this would be done through a "Change Order Form" at the time of construction and should not be included as part of this ITT.

Question #1: What is the weight of the heaviest fire truck?

**Answer #1: 20,000 lbs.**

I/We hereby verify that we have considered this addendum in our proposal submission.

\_\_\_\_\_  
Proponent's Signature

\_\_\_\_\_  
Date

All inquiries relating to ITT CS-20-13 must be emailed to:  
Bonnie Seitz, Community Public Safety Assistant, [bseitz@rdffg.bc.ca](mailto:bseitz@rdffg.bc.ca)