



November 10, 2020

ADDENDUM No. 2

**Invitation to Quote CS-20-22
SUPPLY OF WATER BLADDERS AND HOSES**

*The addendum is being issued prior to the closing of the invitation to quote (ITQ) to provide further information, make changes to, or to clarify the ITQ documents and is to be read, interpreted and coordinated with all other parts of the ITQ documents. In the case of a conflict with the balance of the documents, this Addendum shall govern. **Bidders shall attach a signed copy of this addendum to their quote submission, failure to do so may result in a non-compliant quotation.***

This addendum is being provided in clarification to ITQ CS-20-22 released October 29, 2020.

QUESTION 1: Please state the thread for the nozzles and well as with or without a pistol grip and color of handle and bumper?

ANSWER 1: The hose thread for the 2.5-inch nozzle will need to have BCT thread and the 1.5-inch nozzle will need to have NPSH thread. The Zero Torque nozzle should have a pistol grip included with it, yes pistol grip is necessary. The color will be chosen at the time of order.

I/We hereby verify that we have considered this addendum in our proposal submission.

Proponent's Signature

Date

All inquiries relating to ITQ CS-20-22 must be emailed to:
Bonnie Seitz, Community/Public Safety Assistant
bseitz@rdffg.bc.ca